

VIRGINIA STATE BUILDING CODE TECHNICAL REVIEW BOARD

I N T E R P R E T A T I O N

Interpretation Number: 4/2006

Code: Virginia Statewide Fire Prevention Code (SFPC)

Section No(s): Use of term "building" in the definition of the term "commercial cooking appliance" in Section 602.1.


---

**QUESTION:** Is a trailer or panel-truck considered to be a building under the SFPC, irrespective of whether it's immobilized or anchored?

**ANSWER:** No.

---

This Official Interpretation was issued by the State Building Code Technical Review Board at its meeting of November 20, 2009.

  
Chairman, State Building Code Technical Review Board